

Facility Summary in LIBERTY County in the City of CHESTER

Location: AG AIR INC
LIBERTY COUNTY AIRPORT PO BOX 670
CHESTER, MT 59522 LIBERTY

Sys Fac ID: 26-02182
Last Inspected On: 9/24/2013
Operating Permit Renewal Date: 9/24/2016

Contact: Buster or Dana Ness, (406) 355-4257

Owners/Operators: Ag Air Inc, Owner (406)-759-5191 LIBERTY COUNTY AIRPORT
PO BOX 670
CHESTER MT 59522-0670

Dana Ness, UST Class A Operator
James Briden, UST Class B Operator
Dana Ness, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	21	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
358			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000					

Facility Summary in LIBERTY County in the City of CHESTER

Location: TIBER MARINA
669 TIBER MARINA RD
CHESTER, MT 59522 LIBERTY

Sys Fac ID: 26-03877

Last Inspected On: 7/11/2013

Operating Permit Renewal Date: 9/29/2016

Contact: Mike Hilliard, (406) 759-5080

Owners/Operators: Bureau of Reclamation Billings, Owner

(406)-247-7310

PO BOX 30137
BILLINGS MT 59107-0137

RuthAnn Norick, Operator

(406)-759-5476

PO BOX 655
CHESTER MT 59522

Michael Hilliard, UST Class A Operator

Michael Hilliard, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	5/1/1986	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3997			Excavation Liner	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		7/11/2013	Automatic Tank Gauging 0.2	Deferred	
1,010					

Facility Summary in LIBERTY County in the City of CHESTER

Location: ROOSEVELT SERVICE INC
US HIGHWAY 2 PO BOX 389
CHESTER, MT 59522 LIBERTY

Sys Fac ID: 26-06061

Last Inspected On: 8/6/2013

Operating Permit Renewal Date: 9/29/2016

Contact: Bob Nordstrom, (406) 759-5278

Owners/Operators: Barbara Nordstrom, Owner (406)-759-5278 ROOSEVELT SERVICE INC
PO BOX 389
CHESTER MT 59522-0389

Robert Nordstrom, Owner (406)-759-5278 ROOSEVELT SERVICE INC
PO BOX 389
CHESTER MT 59522-0389

Robert Nordstrom, UST Class A Operator

Duane Aitken, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	24	6/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1752			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/14/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/7/2013			
7	24	6/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1753			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/14/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/7/2013			

Facility Summary in LIBERTY County in the City of CHESTER

Location: FRASER OIL INC CHESTER
US HIGHWAY 2
CHESTER, MT 59522 LIBERTY

Sys Fac ID: 26-13006

Last Inspected On: 12/11/2014

Operating Permit Renewal Date: 3/17/2018

Contact: Jim Fraser, (406) 292-3833

Owners/Operators: Fraser Oil Inc, Owner

(406)-292-3833

PO BOX 770

INVERNESS MT 59530-0770

Cory Fraser, UST Class A Operator

Cory Fraser, UST Class B Operator

Craig Fraser, UST Class B Operator

Jerry Fraser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	21	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1123			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		12/11/2014			
5	21	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1124			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		12/11/2014			
6	21	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1125			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		12/11/2014			

Facility Summary in LIBERTY County in the City of CHESTER

Location: CHESTER SUPERMARKET
1498 US HIGHWAY 2
CHESTER, MT 59522 LIBERTY

Sys Fac ID: 26-13532

Last Inspected On: 12/11/2014

Operating Permit Renewal Date: 3/13/2018

Contact: Harinder Singh, (406) 759-5538

Owners/Operators: Indian Brothers LLC, Owner (406)-759-5538 1498 US HWY 2
CHESTER MT 59522
Chester Supermarket INC, Operator (406)-759-5538 1498 US HWY 2
CHESTER MT 59522
Mike Scott, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3223			None	Double-Walled	Yes
Currently in Use		9/1/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			OPW 1500 , OPW		
2	20	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3224			None	Double-Walled	Yes
Currently in Use		9/1/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000			OPW 1500 , OPW		
3	20	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3225			None	Double-Walled	Yes
Currently in Use		9/1/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
7,000			OPW 1500 , OPW		